



Integrated Device Technology

F1912 Settling Time

- AT0342
- August 15, 2016

Michael J. Virostko
Principal Product Application Engineer



Agenda

- Customer is using three F1912 Digital Step Attenuator to control the power in a channel.
- During testing they are intermittently seeing failures for attenuations values.
- During a conversation the following points were mentioned:
 - Power testing is done approximately every 500 ns.
 - Errors occur mostly at cold temperatures (-40 °C).
 - Testing is done in the parallel mode.



Observations

- We specify the switching time as either 0.9 μs or 1.8 μs when switching for the minimum to maximum attenuation states.
- We specify the switching time in the serial mode.

Specifications apply at $V_{DD} = +3.3\text{ V}$, $T_{CASE} = +25\text{ }^\circ\text{C}$, $F_{RF} = 2000\text{ MHz}$, $P_{in} = 0\text{ dBm}$, Serial Mode ($V_{mode} > V_{IH}$), $Z_{source} = Z_{Load} = 50\ \Omega$ unless otherwise noted. EvKit losses are de-embedded.


Parameter	Symbol	Conditions	Min	Typ	Max	Units
MSB Step Time	T_{LSB}	Start LE rising edge $> V_{IH}$ End $\pm 0.10\text{ dB}$ Pout settling for 15.5 dB to 16.0 dB transition		500		ns
Maximum spurious level on any RF port ⁴	$Spur_{MAX}$			-140		dBm
Maximum Switching Frequency	SW_{FREQ}			25		kHz
DSA Settling time	τ_{SET}	Max to Min Attenuation to settle to within 0.5 dB of final value		0.9		μs
		Min to Max Attenuation to settle to within 0.5 dB of final value		1.8		

Observations

- We do not expect the switching time to change drastically over temperature or by using the parallel mode.
- Testing will show this to be true.



Test Setup




Test Setup (continued)

- Keysight U2021XA is used to capture data since we can capture the full dynamic range (~ 32 dB) and the time measurement is greater than 200 ns.
- Output power is set for 18 dBm.
- Frequency is 1 GHz.




Maximum to Minimum Settling Time

F1912 - Switching Max to Min Attenuation
Data is to the evaluation board




Minimum to Maximum Settling Time

F1912 - Switching Min to Max Attenuation
Data is to the evaluation board




0.5 dB step for Max to Min Attenuation

F1912 Attenuation
Data is to the evaluation Board using Serial Mode
Attenuation change is 0.5 dB (Max to Min)



0.5 dB step for Min to Max Attenuation

F1912 Attenuation
Data is to the evaluation Board using Serial Mode
Attenuation change is 0.5 dB (Min to Max)



Conclusion

- Switching all attenuators simultaneously does not show any difference over temperature or using either Parallel or Serial Mode.
- The datasheet values of 0.9 and 1.8 μs are confirmed.
- There is a slightly different power profile between the Parallel and Serial mode.
- Changing the individual states sequentially show the maximum switching time is 0.72 μs with most being under 0.4 μs .
- We recommend a delay is added to the measurement so the device can settle out.